

Corrigendum –I dated 30.12.2022
to
PROVIDING AND INSTALLATION OF 40HP MOTOR & PUMP (DSM 80/36), AT MMTC
HOUSING COLONY, NEW DELHI-110017

PART II
(BOQ/FINANCIALBID)

No. MMTC/Estate/1010/2022-23

Dated 30.12.2022

S.no	Description of Item (Original)	Description of Item Modified
1	Supplying of 40 HP capacity Horizontal Centrifugal pump set of discharge capacity of : 100 m3 /Hour at minimum head of 55 mtrs, 1450 Rpm, size of suction discharge 100 X 80 mm, Casing material of CI, Impeller- Bronze, Stainless Steel shaft-SS410, Shaft Sleeve-CI, for suitable for operation of 415 Volt Complete as required (Make: Kriloskar Model No. DSM 80/65)	Supplying of 40 HP capacity Horizontal Centrifugal pump set of discharge capacity of : 100 m3 /Hour at minimum head of 55 mtrs, 1450 Rpm, size of suction discharge 100 X 80 mm, Casing material of CI, Impeller- Bronze, Stainless Steel shaft-SS410, Shaft Sleeve-CI, for suitable for operation of 415 Volt Complete as required (Make: Kriloskar Model No. DSM 80/36)